

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. MDB 05

Date: 04/03/2020

It is certified that an inspection team headed by Raman kr. Jha,
Lab. Assistant (Name of officers with
designation) from Public health Eng. Dept., Madhubani (Name of
Department/office) inspected the Pole Star, Jeewach Chowk, Madhubani (Name & Address of
the School) on 03/03/2020 and found that the Pole Star, Jeewach Chowk, Madhubani
(Name of School) has safe drinking water facilities for the students and members of staff of the
institution and is maintaining the hygienic sanitation condition in the school building & the
campus as per the norms prescribed by the central/state/U.T Govt.

The above valid for a period of 04/03/2021

Signature with Seal : Soni Kumar
04/03/2020
CHEMIST
Name : SONI KUMAR Madhubani
Designation : CHEMIST

To,
Pole Star
Jeewach Chowk
Madhubani
(Name of the institution)

FOR POLESTAR
Bhabh Kumar B...
PRINCIPAL - SECRETARY

DISTRICT LEVEL WATER TESTING LABORATORY P.H. DIVISION, MADHUBANI

②

District - Madhubani

Month - March 2022

SN	BLOCK	PANCHAYAT	VILLAGE	Name of Habitation	NEAREST PERSON	PH	TURBIDITY	TOTAL HARDNESS	TOTAL ALKALINITY	CALCIUM	MAGNESIUM	CHLORIDE	IRON	FLOURIDE	SULFATE	NITRATE	TDS	MPN	REMARKS
1	Rahika	Sapta	Ram Nagar	Jibach Chauk	Pole Star school	7.7	2	120	102	35	20.4	30	0.3	0.4	BPL	BPL	244	A	Safe
Min - Max- Permissible Limit						6.5-8.5	00-05	300-600	200-600	75-200	30-100	250-1000	3-1.0	6-1.5	150-400	45	500-1500		

THIS WATER IS FIT FOR DRINKING PURPOSE.

FOR POLESTAR

PRINCIPAL - SECRETARY

P.H. Division, Madhubani

Chemist

Jami Kumar
 04/03/2022

Current year certificate will be uploaded after 5 days